

PAKISTAN STANDARD

**AIR-COOLED AIR CONDITIONERS AND AIR-TO-AIR HEAT PUMPS —
TESTING AND CALCULATING METHODS FOR SEASONAL PERFORMANCE
FACTORS —**

PART: 3 ANNUAL PERFORMANCE FACTOR



All Rights Reserved)

**PAKISTAN STANDARDS AND QUALITY CONTROL AUTHORITY,
STANDARDS DEVELOPMENT CENTRE,
PSQCA Complex Street 7 A Block -3
Scheme -36 Gulistan -e- johar Karachi**

**AIR-COOLED AIR CONDITIONERS AND AIR-TO-AIR HEAT PUMPS — TESTING AND
CALCULATING METHODS FOR SEASONAL PERFORMANCE FACTORS —**

PART: 3 ANNUAL PERFORMANCE FACTOR

0. FOREWORD

- 0.1 This Pakistan Standard was adopted by the authority of the Board of Directors for Pakistan Standards and Quality Control Authority after approval by the Technical Committee for “Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —Part: 3 annual performance factor,” had been approved and endorsed by the Electrotechnical National Standards _____.
- 0.2 This Pakistan Standard was adopted on the basis of ISO: 16358-3 since IEC Standard have been established in 2013, hence it is deemed necessary to adopt the International standard to keep abreast with the latest technology and as par with ISO standard.
- 0.3 This Pakistan Standard is an adoption of ISO: 16358-3 “Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —Part: 3 annual performance factor,” and its use hereby acknowledged with thanks.
- 0.4 This standard is subject to periodical review in order to keep pace with the development in industry. Any suggestions for improvement shall be recorded and placed before the revising committee in due course.
- 0.5 This standard is intended chiefly to cover the technical provisions relating to this standard and it does not include all the necessary provisions of a Contract.

Contents

	Page
Foreword.....	iv
1 Scope.....	1
2 Normative references.....	1
3 Terms and definitions.....	1
4 Symbols.....	3
5 Calculation of annual performance factor (APF) and total annual performance factor (TAPF).....	3
6 Test report.....	3
Annex A (informative) Calculation of total annual performance factor (TAPF).....	4

Only For Research & Training Purpose
 Not For Sale, PSQCA (C)

Air-cooled air conditioners and air-to-air heat pumps — Testing and calculating methods for seasonal performance factors —

Part 3: Annual performance factor

1 Scope

1.1 This part of ISO 16358 specifies the testing and calculating methods for seasonal performance factor of equipment covered by ISO 5151, ISO 13253 and ISO 15042.

1.2 This part of ISO 16358 also specifies the seasonal performance test conditions and the corresponding test procedures for determining the seasonal performance factor of equipment, as specified in [1.1](#), under mandatory test conditions and is intended for use only in marking, comparison, and certification purposes.

1.3 This part of ISO 16358 does not apply to the testing and rating of:

- a) water-source heat pumps or water-cooled air conditioners;
- b) portable units having a condenser exhaust duct;
- c) individual assemblies not constituting a complete refrigeration system; or
- d) equipment using the absorption refrigeration cycle.